



मुख्य अग्निशमन अधिकारी
OFFICE OF THE CHIEF FIRE OFFICER
अण्डमान तथा निकोबार द्वीप समूह
Andaman and Nicobar Islands

Clearance Number : **FS/FCC/2024/1245**

Port Blair dated **04/03/2024**

FIRE CLEARANCE CERTIFICATE

This is to certify that the **UMMAT PUBLIC SCHOOL...** situated at **UMMAT PUBLIC SCHOOL MIDDLE POINT PORT BLAIR ,MIDDLE POINT ,PORT BLAIR** bearing Survey No. **1276/P** have complied with the fire prevention and fire safety requirements in accordance with NBC guidelines and verified by Fire Brigade Officer on **27/02/2024** and the school is safe from fire safety point of view for a period of one (1) year from the date of issue of this FCC, subject to compliance of specific conditions as appended:-

Note:- Conditions for the validity of Fire Clearance Certificate (FCC)

1. The school consists of (G+2) floors and the FCC is for functioning of classes from Nursery to 08th standard.
2. Students of Classes from Nursery to 1st Standard shall be located at ground floor only and the Class 2 students shall be located not above first floor.
3. Building stability and satisfactory electrical installation to be ascertained from concerned agency.
4. FCC shall stand null and void if there is any violation in existing firefighting arrangements.
5. The school building is not as per approved building plan. FCC may not be treated in any case for regularization of unauthorized construction, if any or violation in building plan.
6. All fire safety arrangements provided therein shall be maintained in good working conditions at all time and all staff members shall be well acquainted to operate all fire safety equipments.
7. Any loss of life or property due to non-functional fire safety measures shall be